

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1574:117 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ 07004  
Contact: Ron Dalton (310) 725-2972

**DESIGN:** Model ADT-MD and ADT-MDS motion detector modules. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 18 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use with separately listed fire alarm control units. For indoor use only.

**XLf:** 7300-1388:238

08-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**AUGUST 13, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager